



**ADDENDUM #1**

**October 13, 2020**

**TO: ALL POTENTIAL BIDDERS**  
**FROM: JOSH MEASE, MAINTENANCE DIRECTOR**  
**SUBJECT: WAYNESVILLE MIDDLE SCHOOL A BUILDING**  
**GYM HEAT REPLACEMENT**

**(RFQ# 27-20)**

The following specifications are hereby made a part of the original documents. Bidders shall acknowledge receipt of this addendum by notation in the space provided on the Proposal Form.

**Addendum includes: Additional Features**

**Addendum #1**

**RFP# 27-20**



**ADDENDUM to RFP# 27-20**

**Waynesville Middle School A Building  
Gym Heat Replacement**

Include:

- Haywood County Schools will provide power and disconnect switch to unit.
- Contractor will be responsible from disconnect switch to heating unit.
- Due to floor construction and load rating of floor, scaffolding must be used to install units.
- Contractor will be responsible for their own scaffolding.

-  
If there are any questions, please call Adam Robinson at (828) 508-4986.