



# HAYWOOD

## COUNTY SCHOOLS

MAINTENANCE  
401 Farmview Drive, Waynesville, NC 28786  
P: 828.456.2402 | F: 828.456.2452

Maintenance Director: Zachary Shoaf

---

### ADDENDUM #1

October 21, 2024

**TO: ALL POTENTIAL BIDDERS**  
**FROM: ZACHARY SHOAF, MAINTENANCE DIRECTOR**  
**SUBJECT: DEMOLITION OF STRUCTURES**

**(RFQ 10-24)**

The following specifications are hereby made a part of the original documents. Bidders shall acknowledge receipt of this addendum by notation in the space provided on the Proposal Form.

**Addendum includes:**

- **Fill in the basement area under Central Haywood High School. If debris is used to fill in the basement three (3) feet of dirt must cover debris.**
- **All sewer and water must be capped off**
- **All debris must be removed**
- **Underground oil barrel located at the loading dock on the back side of the school must be removed. With all Environmental qualifications being taken care of.**

**Addendum #1**  
**RFQ 10-24**