



HAYWOOD

COUNTY SCHOOLS

MAINTENANCE
401 Farmview Drive, Waynesville, NC 28786
P: 828.456.2402 | F: 828.456.2452

Maintenance Director: Josh Mease

ADDENDUM #3

January 10, 2022

TO: ALL POTENTIAL BIDDERS
FROM: JOSH MEASE, MAINTENANCE DIRECTOR
SUBJECT: WAYNESVILLE MIDDLE SCHOOL D & E BUILDING
UNIT REPLACEMENT

(RFP# 31-21)

The following specifications are hereby made a part of the original documents. Bidders shall acknowledge receipt of this addendum by notation in the space provided on the Proposal Form.

Addendum includes:

- **Plans/Pictures added (see below)**

Addendum #3
RFP# 31-21



HAYWOOD

COUNTY SCHOOLS

MAINTENANCE
401 Farmview Drive, Waynesville, NC 28786
P: 828.456.2402 | F: 828.456.2452

Maintenance Director: Josh Mease

ADDENDUM to RFP# 31-21

Waynesville Middle School D & E Building Unit Replacement

Include:

[PROPOSAL FORM](#)

**Waynesville Middle School - D & E Building Unit Replacement
RFP# 31-21**

DUE DATE: Wednesday, Jan. 12, 2021 at 10:00 am EST

If there are any questions, please call Adam Robinson at (828) 508-4986.



HAYWOOD COUNTY SCHOOLS

MAINTENANCE
 401 Farmview Drive, Waynesville, NC 28786
 P: 828.456.2402 | F: 828.456.2452

Maintenance Director: Josh Mease

HEAT PUMP SCHEDULE

CIR (LBS)	REMARKS	INDOOR UNIT										OUTDOOR UNIT			
		AHU #	MODEL #	COOLING CAPACITY (TONS)	TOTAL CAP (KW)	E.S.P. (PSI)	O/A (T/M)	VOLUME (CFM)	ELECTRIC HEAT (KW)	POSITION	HP #	MODEL #	COOLING CAPACITY (TONS)	HEATING CAPACITY (BTU)	VOLUME (CFM)
50	1, 3, 6, 8	AHU-52	THC-300	5	2000	5	300	208-1	20	VERTICAL	HP-52	25HQA-40	5	36,200	208-3
50	1, 3, 6, 8	AHU-53	THC-300	5	2000	5	300	208-1	20	VERTICAL	HP-53	25HQA-40	5	36,200	208-3
50	1, 3, 6, 8	AHU-55	THC-300	5	2000	5	300	208-1	20	HORIZONTAL	HP-55	25HQA-40	5	36,200	208-3
50	1, 3, 6, 8	AHU-56	THC-300	5	2000	5	300	208-1	20	VERTICAL	HP-56	25HQA-40	5	36,200	208-3
50	1, 3, 6, 8	AHU-58	THC-300	4	1600	5	190	208-1	15	VERTICAL	HP-58	25HQA-40	4	30,000	208-3
50	1, 3, 6, 8	AHU-60	THC-300	3	1200	5	150	208-1	20	VERTICAL	HP-60	25HQA-30	3	21,400	208-3
23	1, 3, 6, 8	AHU-70	THC-300	5	2000	5	300	208-1	20	VERTICAL	HP-70	25HQA-40	5	36,200	208-3
14	1, 3, 6, 8	AHU-73	THC-300	5	2000	5	300	208-1	20	VERTICAL	HP-73	25HQA-40	5	36,200	208-3
14	1, 3, 6, 8, 11	AHU-74	THC-300	5	2000	5	300	208-1	20	VERTICAL	HP-74	25HQA-40	5	36,200	208-3
14	1, 3, 6, 8	AHU-76	THC-300	5	2000	5	300	208-1	20	VERTICAL	HP-76	25HQA-40	5	36,200	208-3
23	1, 3, 6, 8	AHU-78	THC-300	5	2000	5	300	208-1	20	VERTICAL	HP-78	25HQA-40	5	36,200	208-3



HAYWOOD COUNTY SCHOOLS

MAINTENANCE
401 Farmview Drive, Waynesville, NC 28786
P: 828.456.2402 | F: 828.456.2452

Maintenance Director: Josh Mease

